



PANDUIT PART NO.	BUNDLE DIA.		A	B	C	D	E	F	G	H	J	MAX. PANEL THICKNESS in (mm)	MIN. LOOP TENSILE lbs (N)	CROSS SECTION	WEIGHT 100 pcs lbs (g)
	MIN. in (mm)	MAX. in (mm)													
PRLWP30S-30	.312 (7.9)	1.43 (36)	.05 (1.3)	.38 (9.7)	.47 (11.9)	.47 (11.9)	.65 (16.5)	4.7 (119)	.71 (18)	.266 (6.8)	.30 (7.6)	.118 (3.0)	35 (156)	STANDARD	.36 (163)
PRLWP50S-30	.312 (7.9)	2.18 (55)	.05 (1.3)	.38 (9.7)	.47 (11.9)	.47 (11.9)	.65 (16.5)	7.1 (180)	.71 (18)	.266 (6.8)	.30 (7.6)	.118 (3.0)	35 (156)	STANDARD	.44 (200)

DIMENSIONS IN PARENTHESES ARE IN METRIC UNITS.

PANDUIT CORP. TINLEY PARK, ILLINOIS  
WINGED PUSH MOUNT CABLE TIE  
PRLWP SERIES

UNLESS OTHERWISE SPECIFIED,  
DIMENSIONAL TOLERANCES ARE:  
(.X) ± .1 (.25) (.XXX) ± .020 (.51)  
(.XX) ± .02 (.5) ANGLES ----

UNLESS OTHERWISE SPECIFIED,  
ALL DIMENSIONS ARE GIVEN  
IN INCHES, THIRD ANGLE PROJECTION.

DRAWN BY  
WKS/RLS

MAT'L:

SCALE

NONE

DATE  
10/3/88

HEAT STABILIZED  
NYLON 6.6  
BLACK (-30)

DRAWING NO.

SS-23343

DWG  
A  
SIZE

14	12/16/04	JABO		CHANGED METRIC CONVERSION FROM WHOLE NUMBER TO ONE DIGIT ON DIM. C & D	23343	14									
REV	DATE	BY	CHK	DESCRIPTION	ECN	R	CUST	SUP							