Separate Amplifier Proximity Sensor with Adjustment Potentiometer

# E2C/E2C-H

SM\_E2C\_E2C-H\_DS\_E\_3\_1

# Separate Amplifier Sensor with Sensitivity Adjustment

- · Compact design with smaller Sensor Head.
- Heat-resistance model available for application between -10 and 200°C.



Be sure to read *Safety Precautions* on page 15.

## **Ordering Information**

#### Sensors [Refer to *Dimensions* on page 18.] Standard Models

	Sensor							Amplifier U	nits	
Appeara	Appearance		Stable sensing area * Model		Model	Combination	Model	Power supply/ Output	Timer func- tion	Self-diag- nostic output
	3.5 dia.	0.8 (1	.8) mm		E2C-CR8A 3M	_	E2C-GE4A	DC/ (NPN)		
	3.8 dia.	0.8 (1	.8) mm		E2C-CR8B 3M			DC/		
	M5	1 (2)	mm		E2C-X1A 3M	▶	E2C-GF4A	(PNP)		
Shielded	5.4 dia.	1 (2)	mm		E2C-C1A 3M	_	E2C-WH4A			
	M8	1.5 (3	8) mm		E2C-X1R5A 3M		E2C-JC4AP 2M *	DC/	Yes	Yes
	M12	2 (5)	mm		E2C-X2A 3M			(NPN)		
	M18	5 (	10) mm		E2C-X5A 3M		E2C-JC4A 2M	DC/ (NPN)	Yes	
	M30		10 (18)	mm	E2C-X10A 3M		E2C-AM4A			
Unshielded	40 dia.			20 (50) mm	E2C-C20MA 3M		E2C-AK4A	AC		

\*1. Values in parentheses are for the maximum sensing distances at 23°C.

\* Self-diagnostic output, timer, and DIN Track mounting.

#### **Heat-resistant Model**

		Sensor	O a multi in add a m	Amplifier Unit	
Appearance		Stable sensing area	Model	Combination	Model
	M8	1.5 mm	E2C-X1R5AH	I – M	E2C-JC4CH
Shielded	M12	2 mm	E2C-X2AH		E2C-JC4DH
	M18	5 mm	E2C-X5AH	⊢→	E2C-JC4EH

Note: Characteristics will change if the cable length changes. Do not cut or extend the cable.

#### Accessories (Order Separately) Mounting Brackets [Refer to Dimension on page 21.]

Y92E-F3R5 Y92E-F5R4	E2C-CR8A, for 3.5 dia.	
Y92E-F5R4	FOC C1A for E 4 dia	
	E2C-C1A, for 5.4 dia.	
r to Dimensio	n on page 21.]	
Model	Applicable Amplifier Unit	Remarks
PYF08A	E2C-GE4A E2C-GF4A	Hold-down Clips (Order Separately) PYC-A1 Sold as a set.
P2CF-08	E2C-AM4A	
P2CF-11	E2C-AK4A	
P3G-08	E2C-AM4A	
P3GA-11	E2C-AK4A	
on on page 21	.]	
	Applicable Amplifier Unit	Remarks
or	Model	

Name	Model	Applicable Amplifier Unit	Remarks
	Y92F-30		
Embedded Adapters	Y92F-70	E2C-AM4A/-AK4A	
	Y92F-71		

For details on *Mounting Brackets, Protective Covers, and Sputter Protective Covers*, refer to Accessories on Y92.

# **Ratings and Specifications**

#### **Standard Models**

#### Sensors

Item	Model	E2C-CR8A/ -CR8B	E2C-X1A/ -C1A	E2C-X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C-C20MA		
Sensing distance (at 23°C)		1.8 mm	2 mm	3 mm	5 mm	10 mm	18 mm	50 mm		
Stable sensing Ambient temperature		0 to 0.8 mm	0 to 1 mm	0 to 1.5 mm	0 to 2 mm	0 to 5 mm	0 to 10 mm	0 to 20 mm		
area	At 0 to 40°C	0 to 1.2 mm	0 to 1.5 mm	0 to 2 mm	0 to 2.5 mm	0 to 7 mm	0 to 15 mm	0 to 28 mm		
Different	ial travel	Refer to Ratings	and Specificatio	ons on page 4 for	Amplifier Unit sp	ecifications.				
Detectab	le object	Ferrous metal (	The sensing dista	ance decreases v	vith non-ferrous r	netal. Refer to <i>El</i>	ngineering Data o	on page 7.)		
Standard ject	I sensing ob-	Iron, $5 \times 5 \times 1$ n	ım	Iron, $8 \times 8 \times$ 1 mm	$\begin{array}{c} \text{Iron, } 12 \times 12 \times \\ 1 \text{ mm} \end{array}$	Iron, $18 \times 18 \times 11$ mm	$\begin{array}{c} \text{Iron, } 30 \times 30 \times \\ 1 \text{ mm} \end{array}$	Iron, 50 $\times$ 50 $\times$ 1 mm		
Respons frequenc		1 kHz		800 Hz		350 Hz	100 Hz	50 Hz		
Ambient temperat	ture range	Operating/Stora	ge: –25 to 70°C	(with no icing or	condensation)					
Ambient humidity		Operating/Storage: 35% to 95% (with no condensation)								
Temperature influence         15% max. of sensing distance at 23°C in the temperature range of -25 to 70°C										
Vibration	n resistance	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X and Y directions								
Shock re	esistance	Destruction: 500 m/s <sup>2</sup> 3 times each in X and Y directions								
Degree o	of protection	IEC 60529 IP67, in-house standards: oil-resistant								
Connecti	ion method *2	Pre-wired Models								
Connecti		High-frequency coaxial cable (Standard cable length: 3 m)								
Weight (packed	state)	Approx. 40 g	Approx. 45 g	Approx. 50 g	Approx. 60 g	Approx. 140 g	Approx. 270 g	Approx. 300 g		
	Case	Stainless steel Brass								
Sensing surface		ABS resin								
Materi- als	Cable	Polyethylene								
	Clamping nut		Brass, nickel-pla	ated (except E2C	C-C1A)					
	Toothed washer	Brass, zinc-plated (except E2C-C1A)								
Accesso	ries									

\*1. The minimum value when using the solid-state control output on the Amplifier Unit. Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing distance.
 \*2. Refer to 6 for cable lengths when combining Amplifier Units and Sensors. The characteristic impedance of the high-frequency coaxial cable is 50 Ω.

### **Amplifier Units**

Item	Model	E2C-GE4A	E2C-GF4A	E2C-JC4A E2C-JC4AP	E2C-WH4A	E2C-AM4A	E2C-AK4A	
Power sup age (opera age range	ating volt-	12 to 24 VDC (10 to 30	) VDC), ripple (p-p): 10°	% max. *1	1	1	100 to 240 VAC (90 to 264 VAC) 50/60 Hz	
Current consumpt	tion	25 mA max.		45 mA max.	25 mA max.	50 mA max.	55 mA max.	
Sensing d adjustmer	listance nt range *2	20% min. of rated sens turn potentiometer	sing distance with 4-	20% to 100% of rated	sensing distance with 4	-turn potentiometer		
Differentia adjustmer		Differential travel fixed	(10% max. of sensing (	distance)		1% to 5% of rated ser	nsing distance	
Re-	Solid- state	(Refer to the response	frequency of the Proxir	mity Sensor.)		1		
sponse time	Relay						20 ms max.	
Control outputs	Solid- state	NPN Load resistance: 4.7 kΩ, 100 mA max. (40 VDC max.) (Residual voltage: 1.5 V max.)PNP Load resistance: 4.7 kΩ, 100 mA max. (40 VDC max.) (Residual voltage: 1.5 V max.)NPN Open-collector output (40 VDC max.) (Residual voltage: 0.7 V max.)NPN Open-collector output 200 mA max. (Residual voltage: 0.7 V max.) (Residual voltage: 1.5 V max.)NPN Open-collector output 200 mA max. (Residual voltage: 0.7 V max.) (Residual voltage: 1.5 V max.)			Transistor/photocou- pler 50 mA max. (40 VDC max.) (Residual voltage: 2 V max.)			
	Relay	2A = 1				Relay output, SPDT 2 A at 250 VAC, cos¢ = 1 (resistive load) *3		
				Detection indicator (re Stability indicator (gre				
Operation	mode	Changed with NO/NC	switch.	1	· · · · · · · · · · · · · · · · · · ·	L		
Self-diagn output	nostic (E2C-JC4AP only) Output transistor turns ON when Sen- sor open circuit or un- stable sensing is detected; solid-state NPN open-collector 50 mA max. (40 VDC max.) (Residual voltage: 1 V max.)							
Timer fun	ction			OFF-delay: 40 ±10 ms				
Cable length compensation between Sensor and Amplifier Unit        (E2C-JC4AP only) 3 m/5 m, terminals Short-plate switching Shorted: 1 to 3 m Open: 3 to 5 m       Switched between 3 and 5 m.       Mode switched with 4-portion 4-p		-position switch.						
Ambient temperatu	ire range	Operating/storage: -10	0 to 55°C (with no icing	or condensation)		1		
Ambient humidity r	range	Operating/Storage: 35	% to 85% (E2C-JC4AP	: 35% to 95%) (with no o	condensation)			
Temperati influence	ure	10% max. of sensing distance at 23°C in the temperature range of –10 to 55°C						
Voltage in	fluence	Jence DC Models: ±1% max. of sensing distance at rated voltage in the rated voltage ±20% range AC Models: ±1% max. of sensing distance at rated voltage in the rated voltage ±10% range						
Insulation resistance		50 M $\Omega$ min. (at 500 VE	DC) between current-ca	rrying parts and case				
Dielectric	strength			etween current-carrying etween current-carrying				
Vibration	resistance	Destruction: 10 to 25 H	Iz, 2-mm double ampli- n X, Y, and Z directions	Destruction: 10 to 55 Hz, 1.5-mm double ampli- tude for 2 hours each in X, Y, and Z direc- tions	oli- Destruction: 10 to 25 Hz, 2-mm double amplitude for 2 hours each in th X, Y, and Z directions			

Model Item	E2C-GE4A	E2C-GF4A	E2C-JC4A E2C-JC4AP	E2C-WH4A	E2C-AM4A	E2C-AK4A
Shock resistance	Destruction: 100 m/s <sup>2</sup>	3 times each in X, Y, an	d Z directions			
Life expectancy						Mechanical: 10,000,000 opera- tions min. Electrical: 100,000 operations min.
Connection method	Terminal block		Pre-wired Models (Standard cable length: 2 m)	Terminal block		
Weight (packed state) *4	Approx. 20 g		E2C-JC4A: Approx. 50 g E2C-JC4AP: Approx 80 g	Approx. 80 g	Approx. 140 g	Approx. 250 g
Accessories	Instruction manual		Caution labels, Mounting Bracket, in- struction manual	Instruction manual		

\*1. A full-wave rectification power supply of 24 VDC ±10% (average value) can be used (except for the E2C-GE4□).
\*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.
\*3. Internal relay: G2R-14 DC 12V
\*4. The weight of the Connection Socket is not included.

#### **Heat-resistant Models**

#### Sensors

Item	Model	E2C-X1R5AH	E2C-X2AH	E2C-X5AH			
Detectat	ole object	Ferrous metal (The sensing distance decreases with non-ferrous metal, refer to <i>Engineering Data</i> on page 7.)					
Standard object	d sensing	Iron, $8 \times 8 \times$ 1 mm	Iron, $12 \times 12 \times 11$ mm	Iron, $18 \times 18 \times 11$ mm			
Stable se area	ensing	0 to 1.5 mm	0 to 2 mm	0 to 5 mm			
Different	tial travel	0.04 mm max.		0.1 mm max.			
Respons frequence		300 Hz					
Ambient ture rang	tempera- ge	Operating/Storage densation)	e: -10 to 200°C (wi	th no icing or con-			
Ambient humidity		Operating/Storage: 35% to 95% (with no condensation)					
Tempera influence		±0.2%/°C					
Vibration resistant		Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions					
Shock re	esistance	Destruction: 500 m/s $^2$ 3 times each in X, Y, and Z directions					
Degree of protection		IEC 60529 IP60 *2					
Connect od	ion meth-	Pre-wired Models (Cable length: 3 m) Heat-resistant, high-frequency coaxial cable					
Weight (packed	state)	Approx. 50 g	Approx. 60 g	Approx. 140 g			
0	Case	Brass					
	Sensing surface	PEEK (polyether ether ketone)					
Mate- C	Cable	Fluorine resin					
	Clamping nut	Brass, nickel-plated					
	Foothed washer	Iron, zinc-plated					

Note: Ratings and characteristic are given for 50% of the stable sensing area.
\*1. Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing distance.

\*2. Do not operate the Sensor in areas exposed to water vapor because the enclosure is not waterproof.

#### **Amplifier Units**

Item Model	E2C-JC4CH	E2C-JC4DH	E2C-JC4EH			
Power supply voltage *1 (operating voltage range)	12 to 24 VDC (10 to 30 VDC), ripple (p-p): 10% max.					
Current consump- tion	45 mA max.					
Sensing distance adjustment range *2	20% to 100% of ra 4-turn potentiomet	ated sensing distan ter	се			
Con- trol	NPN open collecto	or, 100 mA max. (4	0 VDC max.)			
out- puts Residual voltage	0.8 V max.					
Indicators	Detection indicato	r (red)				
Operation mode	Changed with NO	/NC switch.				
Cable length compensation	Switched between	Switched between 3 and 5 m.				
Ambient tempera- ture range	Operating/storage: $-10$ to $55^{\circ}$ C (with no icing or condensation)					
Ambient humidity range	Operating/storage: 35% to 85% (with no condensation)					
Temperature influence	±0.08%/°C					
Voltage influence	$\pm 2\%$ max. of sensing distance at rated voltage in the rated voltage $\pm 20\%$ range					
Insulation resistance	50 $M\Omega$ min. (at 500 VDC) between current-carrying parts and case					
Dielectric strength	1,000 VAC, 50/60 Hz for 1 min between current-carry- ing parts and case					
Vibration resistance	Destruction: 10 to 2 hours each in X,	55 Hz, 1.5-mm dou Y, and Z directions	uble amplitude for s			
Shock resistance	Destruction: 100 n tions	n/s² 3 times each in	X, Y, and Z direc-			
Degree of protection	IEC 60529 IP20					
Connection method	Pre-wired Models (Cable length: 2 m)					
Weight (packed state)	Approx. 80 g					
Accessories	Caution labels, Mounting Bracket, instruction manual					

 A full-wave cation power supply of 24 VDC  $\pm 10\%$  (average value) can be used.

\*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.

### **Cable Lengths for Sensor-Amplifier Unit Combinations**

#### **Standard Models**

Sensor Amplifier Units	E2C-CR8A	E2C-CR8B	E2C-X1A	E2C-C1A	E2C- X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C- C20MA
E2C-GE4A		P	estricted to 3	m					
E2C-GF4A			estricted to 5						
E2C-WH4A	Se	Restricted to 3 m or 5 m. Set cable length switch to desired position. *							
E2C-JC4AP		1 to 3 m: Short cable length terminals * 3 to 5 m: Open cable length terminals *							
E2C-JC4A			Restricte	ed to 3 m.					
E2C-AM4A			0 to 5 m			• ••	10 m		
E2C-AK4A	Se	et cable lengtl	n switch to de	sired position	l. *	Set cable	e length switc	h to desired p	osition. *

Note: The standard cable length is 3 m. Models with 5-m or 10-m are manufactured upon order.

\* Refer to page 14 for the operation of cable length switching.

#### **Heat-resistant Models**

Sensor Amplifier Units	E2C-X1R5AH	E2C-X2AH	E2C-X5AH			
E2C-JC4CH						
E2C-JC4DH	Set 3 m/5 m cable length switch to desired position.					
E2C-JC4EH						


Note: The standard cable length is 3 m. Models with 5-m are manufactured upon order.


### **Self-diagnostic Function**

The self-diagnostic output transistor will turn ON in the following cases. (The output will turn ON for any of these conditions individually.) (1) Sensor open circuit: Transistor will turn ON the instance there is an open circuit for the Sensor (including the cable).

Sensor Connected

#### Sensor Open Circuit






Note: When the E2C-X2A Sensor is used, 93% is 96% and 107% is 104%. \* The self-diagnostic output may turn ON if the sensing objects moves a low speed. In actual application, include an ON-delay timer circuit or other suitable measure.

(2) Detection: The output will turn ON if a sensing object is within 93% to 100% of the sensing distance continuously for 0.3 s or longer (e.g., for sensing object position offset).

(3) No detection: The output will turn ON if a sensing object is within 100% to 107% of the sensing distance continuously for 0.3 s or longer (e.g., when background is influencing detection).


### Indicators

- The detection indicator lights when a sensing object approaches the sensing distance to indicate that a sensing object has been detected.
- The stability indicator lights when the sensing object approaches within 93% of the sensing distance or moves away from 107% of the sensing distance to indicate a stable sensing or non-sensing condition.




# **Engineering Data (Typical)**


#### Sensing Area E2C-CR8



#### E2C-X1A/-C1A




#### E2C-X1R5A




### E2C-X2A


E2C-C20MA




### E2C-X5A




#### E2C-X1R5AH + E2C-JC4CH




#### E2C-X10A




#### E2C-X2AH + E2C-JC4DH







E2C-X5AH + E2C-JC4EH




# Influence of Sensing Object Size and Material E2C-CR8







#### E2C-X5A




#### E2C-X1R5AH + E2C-JC4CH




E2C-X1R5A









#### E2C-C20MA




E2C-X5AH + E2C-JC4EH



### E2C-X10A




#### E2C-X2AH + E2C-JC4DH






### I/O Circuit Diagrams





### **Connections between Amplifier Unit and Sensor**





Note: Characteristics will change if the cable length changes. Do not cut or extend the cable.


### **Load Connections**













The E2C-AK4A supports relay and transistor/photocoupler outputs, and the E2C-AM4A supports both NPN and PNP open-collector output. They can be connected to a wide variety of load types and power polarities.

# Nomenclature and Timing Charts

#### **Amplifier Units**

	E2C-G□4A
Operation switch Changes NO/NC.	(voltage output) L OFF
OFF-delay operation_ terminals Stability indicator_	E2C-JC4A Mounting screw Timing Chart Detection indicator (red) Operation switch Not Changes NO/NC. Detection indicator (red) OFF Detection indicator (red) OFF





\* Cable Length Compensation Switching

Set this switch to the proper setting depending on whether the standard cable length is being used or the cable has been cut shorter.

#### **Amplifier Unit Switch Settings**

Applicable Sensors	Cable length	0 to 1 m	1 to 2 m	2 to 3 m	3 to 4 m	4 to 5 m	5 to 6 m	6 to 7 m	7 to 8 m	8 to 9 m	9 to 10 m
E2C-CR8A E2C-CR8B E2C-X1A E2C-C1A E2C-C1A E2C-X1R5A		A B C D	A B C D	A B C D	A B C D	A B C D					
E2C-X2A E2C-X5A E2C-X10A E2C-C20MA		A B C D									

Note: 1. Mutual Interference Prevention: When mounting Sensors with the same diameter and cable length in parallel, set the DIP switch to modes that differ by 1 m in cable length. Specifications, however, may not be sufficiently met, so always check operation before actual application. This method cannot be used for the E2C-C20MA.

2. When using the E2C-CR5B + E2C-AM4A (or AK4A), set all the pins on the Amplifier Unit DIP switch to the left.

### **Safety Precautions**

#### Refer to Warranty and Limitations of Liability.

### <u> WARNING</u>

This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.




#### Precautions for Correct Use

Do not use the Encoder under ambient conditions that exceed the ratings.

#### Design

#### Influence of Surrounding Metal

When mounting the Sensor within a metal panel, ensure that the clearances given in the following table are maintained. Failure to maintain these distances may cause deterioration in the performance of the Sensor.



#### Influence of Surrounding Metal

tal (Unit: mm)

I	d	D	m
	(3.5)		2.4
	(5)		3
0	(5.4)	0	5
	(8)		4.5
	(12)		6
	(18)		15
	(30)		30
25	120	40	60
		0 (5) (5.4) (8) (12) (18) (30)	(5)           (5.4)           0         (8)           (12)           (18)           (30)

Note: Values in parentheses for diameter d are the outer diameters of Shielded Models.

#### **Mutual Interference**

When installing Sensors face-to-face or side-by-side, ensure that the minimum distances given in the following table are maintained. Mutual interference can be prevented by using the cable length compensation switch, but doing so will also change coil characteristics. Specifications such as temperature specifications and sensing distance, may not be sufficiently met, so always check operation before actual application.

This method cannot be used for the E2C-G□4A, E2C-JC4A, E2C-C20MA.



#### Mutual Interference (Unit: mm)

Model	Distance	Α	В	
E2C-CR8				
E2C-X1A		20	15	
E2C-C1A		20		
E2C-X1R5A(	H)			
E2C-X2A(H)		30	20	
E2C-X5A(H)		50	35	
E2C-X10A		100	70	
E2C-C20MA		300	200	

Note: The above values are for a differential travel setting of 5%.

#### Mounting

• Do not use excessive force when tightening the nuts on the E2C-X and E2C-C20MA. A washer must be used with the nut.




Model	Torque
E2C-X1A	0.98 N⋅m
E2C-X1R5A(H)	2.0 N⋅m
E2C-X2A(H)	5.9 N⋅m
E2C-X5A(H)	15 N⋅m
E2C-X10A	39 N⋅m
E2C-C20MA	15 N⋅m

Note: The above leeways in tighten torque assume that a toothed washer is being used.

#### Mounting Unthreaded Cylindrical Models

When using a set screw, tighten it to a torque of 0.2  $N{\cdot}m$  max.



Y92E-F3R5 Mounting Bracket (for 3.5 dia.) (Order Separately)



The Y92E-F5R4 (for 5.4 dia.) is also sold separately.


#### Mounting

#### Mounting the Amplifier Unit

### E2C-JC4A, E2C-JC4□H

Lengthwise Mounting

- (1)Secure the Mounting Bracket with the enclosed M3 screws.(2)Slide the protrusion on the Amplifier Unit into the holes on the Mounting Bracket.
- (3)Secure the Amplifier Unit with mounting screws.
- (4)Secure the cover to the case.




#### Mounting to the Side

(1)Remove the cover screw and mounting screw.

(2)Attached the enclosed M3 screw to the cover and secure the cover to the case.

(3)Secure the Amplifier Unit with M3 screws from the side.




After completing adjustments, attach the enclosed caution label over the adjustment holes to prevent adjustment mistakes.

### E2C-WH4A

#### Mounting Method


(1)Mount to DIN Track as shown in the following diagram.

(2)Hook part (A) at the top of the Amplifier Unit on the DIN Track first and then press in on the Amplifier Unit in the direction indicated by (B).




#### **Removing the Amplifier Unit**

(3)Pull down on the track stopper (C) with a flat-blade screwdriver and then remove the Amplifier Unit from the DIN Track. When using DIN standard 35 track, keep other devices on the track separated from the Amplifier Unit by at least 30 mm to facilitate mounting and removal.




#### E2C-A 4A Using P2CF-11, P2CF-08

When aligning the Amplifier Unit vertically with the Socket, consider the space required for the hooks and allow a leeway of about 20 mm above and below the Amplifier Unit.




#### Mounting Embedded in a Panel

(1)When using the Y92F-30 Embedded Mounting Adapter, insert the Amplifier Unit into a square hold in the panel, attach the Adapter from the back and press in to reduce the gap with the panel. Then secure the Adapter with the screws.




(2)When using the Y92F-70 or Y92F-71 Embedded Mounting Adapter, just press the Amplifier into a square hole in the panel. If the panel coating is too thick and the hooks do not lock in place, spread the hooks from the back by pushing in the directions of the arrows.




#### **Removing the Amplifier Unit**

• When the Amplifier Unit is mounted using the Y92F-30, loosen the screws on the adapter, spread the hooks at the top and bottom, and remove the Adapter.



• Using Y92F-70, Y92F-71 Press in on the hooks with your thumb and forefinger and press forward on the Amplifier Unit.



#### • Wiring

#### Self-diagnostic Output

When not using the self-diagnostic output, connect the orange wire to 0 V or cut it and wrap it with insulation tape so that it does not come into contact with other terminals.


#### Miscellaneous

The sensor does not have a water-resistant structure. Do not use it where it would be subjected to water or water vapor.

### Dimensions

(Unit: mm) Tolerance class IT16 applies to dimensions in this data sheet unless otherwise specified.


# Main Units




#### **Mounting Hole Dimensions**


Model	Model F (mm)		F (mm)	Model	F (mm)	
E2C-CR8A	3.7-dia. +0.3	E2C-X1A	5.4-dia. +0.5 0	E2C-X5A	18.5-dia. +0.5	
E2C-CR8B	4.0-dia. <sup>+0.3</sup>	E2C-X1R5A	8.5-dia. <sup>+0.5</sup>	E2C-X10A	30.5-dia. +0.5 0	
E2C-C1A	5.7-dia. +0.3 0	E2C-X2A	12.5-dia. $^{+0.5}_{0}$	E2C-C20MA	18.5-dia. $^{+0.5}_{0}$	








\*1. After completing adjustments, attach the caution label to prevent adjustment mistakes
\*2. Not required when mounting to DIN Track.
\*3. 4-dia. vinyl-insulated round cable with 3 conductors (Conductor cross section: 0.2 mm<sup>2</sup>, Insulator diameter: 1.2 mm), Standard length: 2 m
The cable can be extended up to 200 m (separate metal conduit).




#### Accessories (Order Separately) Mounting Bracket



31.2 max

#### **Back Connection Sockets**



#### **Read and Understand This Catalog**

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

#### Warranty and Limitations of Liability

#### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

#### **Application Considerations**

#### SUITABILITY FOR USE

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- · Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- · Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

#### Disclaimers

#### CHANGE IN SPECIFICATIONS

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

#### DIMENSIONS AND WEIGHTS

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

#### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

#### ERRORS AND OMISSIONS

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2008.11

In the interest of product improvement, specifications are subject to change without notice.

#### OMRON Corporation Industrial Automation Company

http://www.ia.omron.com/