

Special-Purpose Proximity Sensor

Threaded Cylindrical Inductive Sensor with Separate Amplifier Provides Precision Linear Analog Output and a Discrimination Output

- Linear 4 to 20 mA output for target to sensor distance
- Position measurements accurate to ±0.0006 mm with 0.05% full scale resolution
- Adjustable setpoint controls switching output rated 100 mA is NO/NC selectable
- Amplifier has power ON, target detected, and discrimination output indicators
- AC amplifier has universal voltage rating 90 to 264 VAC
- DC amplifier rated 10 to 30 VDC
- Sensors available in standard 8, 12, 18, 30 mm sizes with sensing distances up to 10 mm



Sensing	Supply voltage	Output		
	90 to 264 VAC, 50/60 Hz amplifier or 10 to 30 VDC amplifier		-Қ	
1.5, 2, 5, 10 mm		4 to 20 mA	100 mA, 40 VDC	

Ordering Information

SENSOR

Sensor type		Shielded				
Part number	3 m (9.8 ft) cable	E2CA-X1R5A	E2CA-X2A	E2CA-X5A	E2CA-X10A E2CA-X10A-5M	
	5 m (16.4 ft) cable	E2CA-X1R5A-5M	E2CA-X2A-5M	E2CA-X5A-5M		
Size		M8	M12	M18	M30	
Nominal sensing		0.3 to 1.5 mm	0.4 to 2.0 mm	1 to 5 mm	2 to 10 mm	
distance		(0.01 to 0.06 in)	(0.02 to 0.08 in)	(0.04 to 0.20 in)	(0.08 to 0.39 in)	

AMPLIFIER

Required sensor		E2CA-X1R5A/-5M	E2CA-X2A/-5M	E2CA-X5A/-5M	E2CA-X10A/-5M
Part	AC power supply	E2CA-AN4C	E2CA-AN4D	E2CA-AN4E	E2CA-AN4F
number	DC power supply	E2CA-AL4C	E2CA-AL4D	E2CA-AL4E	E2CA-AL4F
Outputs		Linear output, 4 to 20 mA	; Switching output, sele	ctable NO or NC trans	istor

ACCESSORIES

Description	Part number	
Mounting brackets for sensors	Fits M8 size sensors	Y92E-B8
	Fits M12 size sensors	Y92E-B12
	Fits M18 size sensors	Y92E-B18
	Fits M30 size sensors	Y92E-B30
Sockets for amplifiers	Combination bottom surface and track mounting socket with screw terminals	P2CF-11
	Back mounting socket with screw terminals for panel mount applications	P3GA-11
	Circuit board socket with solder terminals	PL-11

(This table continues on the following page.)

Specifications Table — continued from previous page

Description		Part number
Panel mounting adapter for ampli	Y92F-30	
Protective covers for amplifier	Y92A-48	
	Y92A-48D	
Mounting track	DIN rail, 50 cm (1.64 ft) length	PFP-50N
	DIN rail, 1 m (3.28 ft) length	PFP-100N
	PFP-M	
	Spacer	PFP-S

■ REPLACEMENT PARTS

Description		Part number
Mounting hardware includes one pair of metal nuts and washers	Fits M8 size sensors (supplied with each sensor)	M8-MHWS
	Fits M12 size sensors (supplied with each sensor)	M12-MHWS
	Fits M18 size sensors (supplied with each sensor)	M18-MHWS
	Fits M30 size sensors (supplied with each sensor)	M30-MHWS

Specifications —

■ SENSOR

Part number		E2CA-X1R5A/-5M	E2CA-X2A/-5M	E2CA-X5A/-5M	E2CA-X10A/-5M			
Sensor type		Inductive						
Body	Size	M8	M12	M18	M30			
	Туре	Shielded	Shielded					
Required am	plifier	E2CA-AL4C or E2CA-AN4C	E2CA-AL4D or E2CA-AN4D	E2CA-AL4E or E2CA-AN4E	E2CA-AL4F or E2CA-AN4F			
Detectable of	oject type	Metallic objects						
Effective max sensing dista (with standar	timum nce d target)	1.5 mm (0.06 in)	2 mm (0.08 in)	5 mm (0.20 in)	10 mm (0.39 in)			
Usable sensi (with standar	ng range d target)	0.3 to 1.5 mm (0.01 to 0.06 in)	0.4 to 2.0 mm (0.02 to 0.08 in)	1 to 5 mm (0.04 to 0.20 in)	2 to 10 mm (0.08 to 0.39 in)			
Standard targ (mild steel, L	get size x W x H)	8 x 8 x 1 mm (0.32 x 0.32 x 0.04 in)	12 x 12 x 1 mm (0.47 x 0.47 x 0.04 in)	18 x 18 x 1 mm (0.71 x 0.71 x 0.04 in)	30 x 30 x 1 mm (1.18 x 1.18 x 0.04 in)			
Response frequency		10 kHz		5 kHz	3 kHz			
Indicators		Not provided						
Materials	Housing	Nickel-plated brass						
	Sensing face	Plastic, acrylonitoryl butad	iene styrene					
	Cable sheath	Plastic, polyethylene						
Mounting		Two lock washers and M8 nuts included. Bracket Y92E-B8 optional.	Two lock washers and M12 nuts included. Bracket Y92E-B12 optional.	Two lock washers and M18 nuts included. Bracket Y92E-B18 optional.	Two lock washers and M30 nuts included. Bracket Y92E-B30 optional.			
Connections	Prewired	2-conductor shielded cable	e: 3 m (9.8 ft) length (E2CA- 5 m (16.4 ft) length (E2CA	X===A) -X===A-5M)				
Weight with c	able	40 g (1.4 oz.)	60 g (2.1 oz.)	140 g (5.0 oz.)	160 g (5.7 oz.)			
Enclosure	UL							
ratings	NEMA	1, 4, 6, 12, 13						
	IEC 144	IP67						
Approvals UL								
	CSA	_						
Ambient operating temperature		-25° to 70°C (-13° to 158° F) -10° to 55°C (14° to 131°F)						
Vibration		10 to 55 Hz, 1.5 mm (0.06	in) double amplitude		10 to 25 Hz, 2 mm (0.08 in) double amplitude			
Shock		Approx. 50 G			Approx. 10 G			

■ AMPLIFIER

Part number		E2CA-A□4C	E2CA-AQ4D	E2CA-AQ4E	E2CA-AQ4F				
Supply	AC types	S		90 to 264 VAC, 50/60 Hz (E2CA-AN4□)					
voltage	DC types	DC types		10 to 30 VDC (E2CA-AL4)					
Current AC types				60 mA max. (E2CA-AN4□)					
consumption DC types				70 mA max. (E2CA	-AL4□)				
Required sens	or			E2CA-X1R5A	E2CA-X2A	E2CA-X5A	E2CA-X10A		
Linear	Output ra	ange		4 to 20 mA					
output	Resolution	on		0.05% to full scale					
characteristics	Linearity	,		± 2.0% of full scale ± 1.5% of full scale ± 2.0% of full scale					
	Respons	se fre	quency	10 kHz		5 kHz	3 kHz		
	Adjustme	ent	4 mA	Adjustment to 4 mA	A at 20% of effective	maximum detectin	g distance		
			20 mA	Adjustment to 20 m	A at effective maxin	num detecting dista	nce		
Switching	Operatio	on mo	de	NO or NC, switch s	electable				
output characteristics	Detecting sensitivit	g dist ty	ance	Adjustable (within s	sensor's "Usable De	tecting Range")			
	Different	ial tra	avel	Fixed, 1 to 5% of d	etecting distance				
	Control	Туре	9	Transistor, SPST					
	output	Max	. load	100 mA, 40 VDC					
		Max	. on-state	2 VDC					
	voltage drop		age drop						
	Respons	se fre	quency	3 kHz		1.5 kHz	1 kHz		
Circuit protection	Switchin short-cire	g out cuit	put	Not provided					
	DC power supply reverse polarity		oply ty	Provided					
	Weld-fiel	Neld-field immunity		Not provided					
	RFI imm	unity		Not provided					
Indicators				Power ON (POWER), Linear Range (SPAN), and Switching Output ON (OPER)					
Materials	Housing			Plastic					
Mounting				Requires P2CF-11, P3GA-11 or PL11 sockets (not included); order separately from Accessories. Adapter Y92F-30 for panel mounting the amplifier (optional); order separately from Accessories.					
Connections				Plated steel screw terminals (P2CF-11 and P3GA-11 sockets); Solder terminals (PL11 socket)					
Weight without	AC types	S		250 g (8.8 oz.)					
socket	DC types	s		120 g (4.2 oz.)					
Enclosure	UL			_					
ratings	NEMA			1					
	IEC 144			IP40					
Approvals	UL			—					
	CSA			—					
Ambient opera	ting temp	peratu	ire	–10° to 55°C (–14°	to 131°F)				
Vibration				10 to 25 Hz, 2 mm	(0.08 in) double am	plitude			
Shock				Approx. 10 G					

Nomenclature

■ AMPLIFIER

E2CA =



Operation

■ FUNCTION — AMPLIFIER

Clas	sification	Function				
O U T P	Linear output	An analog 4 to 20 mA output signal proportional to the distance from the target to the face of the sensor within the range of the 4 mA linear setpoint to the 20 mA setpoint.				
Ŭ	Switching output	A 100 mA, 40 VDC rated transistor output (separate power source required) adjustable within the range of the 4 mA linear setpoint and 20 mA linear setpoint.				
N	Power ON	Red LED illuminated when amplifier is connected to power source and energized.				
D I C A	Operation	Red LED illuminated when the target is present within the range from the minimum sensing distance to the target setpoint distance.				
O R S	Span	Green LED illuminated when the target is present within the range of the 4 mA linear setpoint and the 20 m linear setpoint.				
	Cable length selector switch	Set to the length of cable (3 or 5 meters) supplied on the sensor head.				
A D J	4 mA linear adjustment	Used to set the analog output at 4 mA when the target is at 20% of the rated sensing distance. Adjustment method 1.				
U S T M	20 mA linear adjustment	Used to set the analog output at 20 mA when the target is at 100% of the rated sensing distance. Adjustment method 1.				
N	Sensitivity	Used to set the target distance that turns on the switching output.				
Ś	Mode selector switch	Determines the logic of the switching output circuit. In the NO position, the target turns on when the target is present between the minimum sensing distance and the target setpoint distance. In the NC position, the switching output turns on when the target is beyond the target setpoint distance.				

TIMING CHART



■ LINEAR OUTPUT ADJUSTMENTS

Choose one of the two adjustment methods for setting the LINEARITY adjuster. Adjustment of the 4 mA and 20 mA LINEARITY adjusters must be performed with the standard target at positions of 20% and 100% of the rated detecting distance away from the sensor.

Linearity Adjustment Method 1

E2CA

1. Connect an ammeter across terminals 1 and 2. The illustration shows the sensor connected to an amplifier through socket P2CF-11.



2. Place the standard target at 20% of the rated detecting distance away from the sensor unit.



 Turn the 4 mA LINEARITY adjuster slowly clockwise (to increase the output current) or counterclockwise (to decrease the output current). Set the adjuster to a position that reads 4 mA output on the ammeter.



4. Place the standard target at the rated detecting distance.



 Turn the 20 mA LINEARITY adjuster slowly clockwise (to increase the output current) or counterclockwise (to decrease the output current). Set the adjuster to a position that reads 20 mA output on the ammeter.



 To fine tune the adjustment accuracy of the output current, repeat the adjustment steps for 4 mA and 20 mA LINEARITY adjusters.

Linearity Adjustment Method 2

1. Set the standard target at 20% of the rated detecting distance away from the sensor.



 Turn the 4 mA LINEARITY adjuster counterclockwise so that the SPAN indicator remains OFF. Then slowly turn the adjuster clockwise until the indicator illuminates. Stop turning the adjuster at the position where the SPAN indicator illuminates.



3. Set the standard target at the rated detecting distance away from the sensor.



4. Slowly turn the 20 mA LINEARITY adjuster clockwise until the SPAN indicator goes OFF. Then turn the adjuster counterclockwise until the indicator illuminates. Stop turning the adjuster when the SPAN indicator illuminates.



SENSITIVITY ADJUSTMENTS

Place the standard target at the specified position. If the target moves in parallel with the surface of the sensor unit, make the adjustment after determining the position using the following procedure.

 Adjust the linear output according to Adjustment Method 1 or 2.



2. Calculate detecting distance X using the following formula:

 $X = \frac{S}{0.8}$ S = setting distance

3. Adjust the distance between the sensor and the object to be detected to distance X.



Slowly turn the SENSITIVITY adjuster clockwise (toward HIGH) and stop turning when the OPER. indicator illuminates. Move the target to confirm that the OPER. indicator illuminates when the object to be detected is at the specified position and that the indicator goes OFF when the target is moved away from that position.

If the target moves in parallel with the surface of the sensor unit, place the sensor at distance S.

E2CA -

SELECTOR SWITCHES

Selection of Operation Modes

OUTPUT NO 🔳 NC	The output transistor turns ON when the target is detected.
OUTPUT NO 🔲 NC	The output transistor turns ON when the target is not being detected.

Compensation for Different Cable Lengths

Set the CABLE selector switch to the required position according to the length of the sensor cable being used: 3 m (9.8 ft) or 5 m (16.4 ft).

CABLE 3 m 🔳 5 m	To use sensors with 3 m (9.8 ft) cable length.
CABLE 3 m 🚺 5 m	To use sensors with 5 m (16.4 ft) cable length.

Dimensions

Unit: mm (inch)

SENSORS

M8 Size E2CA-X1R5A, E2CA-X1R5A-5M



M18 Size E2CA-X5A, E2CA-X5A-5M



AMPLIFIERS

E2CA-AL4, E2CA-AN4



M12 Size E2CA-X2A, E2CA-X2A-5M



M30 Size

E2CA-X10A, E2CA-X10A-5M



≤.

(top view)

000

Terminal Arrangement

■ SOCKETS FOR AMPLIFIERS

E2CA =

P2CF-11 Track-Mount Socket with Screw Terminals





P3GA-11 Back-Mounting Socket with Screw Terminals





PL11 Circuit Board Socket with Solder Terminals



(bottom view)

Terminal Arrangement



Mounting Holes Two 3.5 dia. or two M3 through holes





MOUNTING TRACK AND ACCESSORIES PFP-100N/PFP-50N DIN Rail Track PFP-M End Plate





■ Y92A-48, Y92A-48D OPTIONAL PROTECTIVE COVERS FOR AMPLIFIERS

Hard plastic cover Y92-48 and soft plastic cover Y92A-48D snap onto the front of the amplifier to protect it from dust, dirt and water drip. The Y92A-48 hard plastic cover projects 4 mm from the front of the amplifier. Y92A-48D soft plastic cover fits snugly over the front.



35 3

37.3

000



Terminal Arrangement

Mounting Holes

Two 4.5 dia.

holes

40 +0 2

(1.57 ±0.008)

two through holes.

Note: The socket can be mounted on DIN

rail track or surface mounted using

(bottom view)





E2CA

■ Y92F-30 OPTIONAL PANEL MOUNTING ADAPTER FOR AMPLIFIERS



E2CA -





OPTIONAL MOUNTING BRACKETS FOR SENSORS



Part	Drawing	dimensior	Applicable				
number	А	В	С	D	E	F	sensor models
Y92E-B8	18±0.2	10 max.	18	8 dia.	28 max.	M4 x 20 bolt	E2CA-X1R5A, E2CA-X1R5A-5M
Y92E-B12	24±0.2	12.5 max.	20	12 dia.	37 max.	M4 x 25 bolt	E2CA-X2A, E2CA-X2A-5M
Y92E-B18	32±0.2	17 max.	30	18 dia.	47 max.	M5 x 32 bolt	E2CA-X5A, E2CA-X5A-5M
Y92E-B30	45±0.2	17 max.	50	30 dia.	60 max.	M5 x 50 bolt	E2CA-X10A, E2CA-X10A-5M

Engineering Data

■ OPERATING DISTANCE VS. OUTPUT CURRENT











M30 Size Sensor E2CA-X10A

M12 Size Sensor



DETECTING DISTANCE VS. LINEARITY (SQUARE AND RECTANGULAR OBJECTS)

M8 Size Sensor





M18 Size Sensor E2CA-X5A





■ DETECTING DISTANCE VS. LINEARITY (CYLINDRICAL OBJECTS)

M8 Size Sensor E2CA-X1R5A





M30 Size Sensor



M18 Size Sensor E2CA-X5A



Installation

E2CA :

OUTPUT CIRCUIT DIAGRAM



■ CONNECTIONS BETWEEN SENSOR AND AMPLIFIER

Note: The illustrations show the terminal arrangement viewed from the rear of the socket that is coupled to the amplifier.

DC Amplifier and Sensor

AC Amplifier and Sensor



CONNECTION OF LINEAR OUTPUT

Note: The illustration shows the linear output connected to a resistive load.



* Resistance R when E2CA-AL4 is used: 300 Ω max. at 24 V/150 Ω max. at 12 V Resistance R when E2CA-AN4 is used: 300 Ω max.

E2CA

■ CONNECTION OF SWITCHING OUTPUT

A transistorized photocoupler output is used for the switching output of the E2CA-A amplifier unit, which offers flexibility for switching different loads and power supply polarity selection.



MOUNTING SENSORS

Effects of Surrounding Metals

Shielded E2CA proximity sensors may be mounted flush with a metallic panel. Be sure to provide a minimum distance as shown in the table to prevent the sensor from being affected by metallic objects other than the target.



Drawing	Sensor model								
dimension	E2CA-X1R5A		E2CA-X2A		E2CA-X5A		E2CA-X10A		
	mm	inch	mm	inch	mm	inch	mm	inch	
L	0	0	0	0	0	0	0	0	
d (dia.)	8	0.32	12	0.47	18	0.71	30	1.18	
D	0	0	0	0	0	0	0	0	
m	4.5	0.18	6	0.24	15	0.59	30	1.18	

Mutual Interference

To prevent mutual interference between two sensors, be sure to space the two sensors at a distance greater than that shown in the table.



Drawing	Sensor model								
dimension	E2CA-X1R5A		E2CA-X2A		E2CA-X5A		E2CA-X10A		
	mm	inch	mm	inch	mm	inch	mm	inch	
А	20	0.79	30	1.18	50	1.97	100	3.94	
В	15	0.59	20	0.79	35	1.38	70	2.76	

Tightening Force



Do not exceed the maximum torque listed in the table.

Sensor model	Maximum torque			
	kg-cm	in-lbs		
E2CA-X1R5A	20	17		
E2CA-X2A	60	52		
E2CA-X5A	150	130		
E2CA-X10A	400	346		

MOUNTING AMPLIFIERS

Track-Mount Installation Using P2CF-11 Socket

The P2CF-11 socket has two hooks that secure the E2CA amplifier to the socket. Be sure to allow at least 20 mm (0.79 in) clearance above and below the socket to gain access and to release the hooks for servicing and maintenance. The P2CF-11 socket may also be used for surface mounting the amplifier using the two through holes.



OMRON

Panel-Mount Installation Using Y92F-30 Adapter and P3GA-11 Socket

Insert the E2CA amplifier through the panel cutout. Push the Y92F-30 adapter from the rear of the amplifier as far forward toward the panel as possible. Then tighten the two retaining screws. Wire the P3GA-11 socket, then push it onto the rear of the amplifier. To release the adapter, lift the tab at the rear of the adapter.

Several E2CA amplifiers may be panel mounted close together using Y92F-30 adapter as shown here. When mounting two or more amplifiers in a vertical line, arrange the adapters so that their molded tabs are positioned on the right and left sides. When mounting two or more amplifiers in a horizontal line, arrange the adapters so that their molded tabs are positioned on the top and bottom sides.

Panel Cutout for Side-by-Side Mounting of Two Amplifiers

NOTE: DIMENSIONS ARE SHOWN IN MILLIMETERS. To convert millimeters to inches divide by 25.4.

OMRON ELECTRONICS LLC.

One East Commerce Drive Schaumburg, IL 60173 1-800-55-OMRON

Cat. No. GC MSEN4

04/01

OMRON ON-LINE

Global - http://www.omron.com USA - http://www.omron.com/oei Canada - http://www.omron.com/oci

Specifications subject to change without notice.

OMRON CANADA, INC.

885 Milner Avenue Scarborough, Ontario M1B 5V8 416-286-6465

Printed in the U.S.A.