High Precision, Remote Type, 2-color Display Digital Pressure Sensor Series PSE540/560




Pressure Sensor Controller Series PSE300


Response Time **1** ms

Set Pressure Resolution 1/1000

Can be mounted in close proximity with each other either horizontally or vertically.



Connection



2 outputs + Analog output or auto shift input

Compact Pressure Sensor for Pneumatics

ZSE□ ISE□

PSE

ZSE3

PS

ZSE:

ZSP

ISA2

IS

ZSM

PF2□


IF□

Data

Series **PSE540**

Weight **2.9** g

Dimension **9.6** x **20.8** x **18** mm




Pressure Sensor for General Purpose Fluids

Series PSE560

1*IP*65

Wetted Material
Stainless steel 316L

Copper-free
 Oil-free (Single diaphragm)





Variations

Compact Pressure Sensor for Pneumatics

Series PSE540

P. 16-3-25

Male thread type



M3 x 0.5 R 1/8 (With M5 female thread) M5 x 0.8 NPT 1/8 (With M5 female thread)

Plug-in reducer type



ø4 plug-in reducer ø6 plug-in reducer

M5 female thread, through type



M5 x 0.8



M5 x 0.8 (With mounting hole)

Pressure Sensor for General Purpose Fluid Series PSE560

P. 16-3-27

P. 16-3-36

Male thread type



R 1/8, 1/4 (With M5 female thread) NPT 1/8, 1/4 (With M5 female thread) URJ 1/4, TSJ 1/4

Female thread type



Rc 1/8

Applicable fluid example

Argon Nitrogen Hydraulic fluid Air containing drainage Ammonia Silicon oil Lubricating oil Freon Carbon dioxide Fluorocarbon

Controller



Series PSE300 **Functions**

- Auto shift function
- Auto preset function
- Precision indicator setting
- Peak and bottom display function
- Key lock function
- Reset function
- Error indication function
- Unit display switching function
- Anti-chattering function

Series		Rated pressure range				
For proumation	PSE541	0 to -101 kPa	Vacuum	-101 kPa	0	
For pneumatics	PSE543	-100 to 100 kPa	Compound pressure	-100 kPa		100 kPa
	PSE560	0 to 1 MPa	Positive pressure		0	√ 1 MPa
For general	PSE561	0 to -101 kPa	Low pressure	-101 kPa	0	
purpose fluids	PSE563	-100 to 100 kPa	Compound pressure	-100 kPa		100 kPa
	PSE564	0 to 500 kPa	Positive pressure		0	∫ 500 kPa



PSE

ZSE3

PS

ZSE;

ZSP

ISA₂

IS

ZSM

PF2□

 $\mathsf{IF}\Box$

Data


Compact Pressure Sensor For General Air

IM5H

through type

(With mounting hole)

Series PSE540



Option/Part No.

•			
Description	Part no.	Note	
Connector for PSE200	ZS-26-E-4	1 pc.	
Connector for PSE300	ZS-28-C	1 pc.	

Specifications

NPT1 /8 (With M5 female thread)

ø4 plug-in reducer

ø6 plug-in reducer

N01

R04

R06

			Conforms to CE marking and UL (CSA) standards.		
Model		PSE541	PSE543		
Rated pressure range		0 to -101 kPa	-100 to 100 kPa		
Proc	of pressure	500 kPa			
Fluid	I	Air, No-corrosive gas	Air, No-corrosive gas, Non-flammable gas		
Pow	er supply voltage	12 to 24 VDC ±10%, Ripple (p-p) 10% or lo	12 to 24 VDC ±10%, Ripple (p-p) 10% or less (With power supply polarity protection)		
Curr	ent consumption	15 mA	or less		
Outp	out specification	Analog output 1 to 5 V (Within rated pressu	re range), Output impedance: Approx. 1 kΩ		
Accuracy (Ambient temperature of 25°C)		±2% F.S. or less			
Linearity		±0.4% F.S. or less			
Repeatability		±0.2% F.S. or less			
Power supply voltage effect		±0.8% F.S. or less			
Enclosure		IP40			
	Operating temperature range	Operating: 0 to 50°C, Stored: -20 to	70°C (No condensation or freezing)		
9	Operating humidity range	Operating/Stored: 35 to 85% RH (No condensation)			
Resistance	Withstand voltage	1000 VAC, 50/60 Hz for 1 minu	ute between live parts and case		
esis	Insulation resistance	50 MΩ between live part	s and case (at 500 VDC)		
ď	Vibration resistance	10 to 500 Hz at whichever is smaller of 1.5 mm amplitude or 98 m/s ² acceleration,			
	Vibration resistance	in X, Y, Z directions, for 2 hours each (De-energized)			
	Impact resistance	980 m/s² in X, Y, Z directions	s, 3 times each (de-energized)		
Temperature characteristics		±2% F.S. or less (based on 25°C)			


Piping Specifications

Model		М3	M5	01	N01	R04	R06	IM5	IM5H
Port size		M3 x 0.5	M5 x 0.8	R1/8	NPT1/8	ø4	ø6	M5 female thread,	M5 female thread,
				M5 x 0.8	M5 x 0.8	plug-in reducer	plug-in reducer	through type	through type (with mounting hole)
	Case	Resin ca	ase: PBT	Resin ca	ase: PBT	PBT		Resin case: PBT	
Material	Case	Fitting: Stainless steel 303 Fitting: C3604B		C3604BD	PBI		Fitting: A6063S-T5		
	Pressure sensing section	Pressure sensor: Silicon, O-ring: NBR							
Sensor cable		3-wire oval cable (0.15 mm²)							
Weight	With sensor cable	42.4 g	42.7 g	49.	3 g	41.4 g	41.6 g	43.3 g	44.1 g
	Without sensor cable	2.9 g	3.2 g	9.	8 g	1.9 g	2.1 g	3.8 g	4.6 g

Internal Circuit

PSE54□

Voltage output type 1 to 5 V Output impedance Approx. 1 $k\Omega$




Dimensions





















	PSE54□-M3	PSE54□-M5
Α	10.8	11.5
В	3	3.5


	PSE54□-R04	PSE54□-R06
Α	ø4	ø6
В	18	20


Common dimensions




PSE54□-IM5









PSE54□-01 N01








PSE54□-IM5H







Specific Product Precautions 1

20 mm or more

Part-A

Be sure to read before handling.

Pressure Sensor

Handling

⚠ Warning

- Do not drop, bump, or apply excessive impact (PSE540: 980 m/s², PSE560: 500 m/s²) while handling. Although the body of the sensor may not be damaged, the inside of the sensor could be damaged and lead to malfunction.
- The tensile strength of the cord is 50 N. Applying a greater pulling force to it can cause malfunction. When handling, hold the body of the sensor—do not dangle it from the cord.
- 3. Do not use pressure sensors with corrosive and/or flammable gases or liquids.

4. Connection of sensor connector Sheath


• Cut the sensor cable as illustrated to the right.

• Referring to the table below, insert each lead wire of the cable at the position

marked with a number corresponding to the color of the lead wire.

Connector	Wire core color				
no.	For PSE200 (ZS-26-E)	For PSE300 (ZS-28-C)			
1	Brown (DC (+))	Brown (DC (+))			
2	Black (OUT: 1 to 5 V)	Not connected			
3	Blue (DC (-))	Blue (DC (-))			
4	Not connected	Black (OUT: 1 to 5 V)			

 Confirm that the numbers on the connector match the colors of the wires and that the wires are inserted to the bottom. Press Part A by hand for temporary fixing.



 A sensor connector cannot be taken apart for reuse once it is crimped. If the wire arrangement is incorrect or



if the wire insertion fails, use a new sensor connector.

 For connection to SMC Series PSE300 pressure switches, use sensor connectors (ZS-28-C) or e-con connectors listed below.

Manufacturer	Part no.
Sumitomo 3M	37104-3101-000FL
Tyco Electronics AMP	1-1473562-4

 For detailed information about e-con connectors, please consult the manufacturers of the respective connectors.

Operating Environment

\land Warning

- The pressure sensors are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. The pressure sensors do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.

Air Supply

⚠ Warning

1. Use of toxic, corrosive or flammable gases
Since the switch uses stainless steel 316L as the material of the

pressure sensor and fittings, do not use **toxic** or **corrosive** gases.

2. Fluid compatibility

Since the switch uses stainless steel 316L as the wetted material (for the pressure sensor and fittings), use fluids that will not corrode this material.

(For the corrosiveness of the fluids, please consult with the manufacturers of the respective fluids.)

Helium leakage test

Helium leakage test is conducted on the welded parts. Use ferrules by Crawford Fittings (Swagelok® fittings) as TSJ fittings, seals and glands by Cajon (VCR® fittings) as URJ fittings. If ferrules, seals, or glands of other brands are to be used, be sure to conduct helium leakage test before using those products.

Controller

Handling

\land Warning

- Do not drop, bump, or apply excessive impact (100 m/s²) while handling. Although the body of the controller case may not be damaged, the inside of the controller could be damaged and cause malfunction.
- 2. The tensile strength of the power supply/output connection cable is 50 N; that of the pressure sensor lead wire with connector is 25 N. Applying a greater pulling force than the applicable specified tensile strength to either of these components can lead to malfunction. When handling, hold the body of the controller—do not dangle it from the cord.

Connection

- Incorrect wiring can damage the switch and cause malfunction or erroneous switch output. Connections should be done while the power is turned off.
- Do not attempt to insert or pull out the pressure sensor or its connector when the power is on. Switch output may malfunction.
- Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- 4. If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.



PSE

^zSE3 PS

ZSE₂

ZSP

ISA2

IS□

ZSM

PF2□

IF□

Data

Specific Product Precautions 2

Be sure to read before handling.

Controller

Operating Environment

⚠ Warning


- Our pressure sensor controllers are CE marked; however, they are not equipped with surge protection against lightning. Lightning surge countermeasures should be applied directly to system components as necessary.
- 2. Our pressure sensor controllers do not have an explosion proof rating. Never use pressure sensors in the presence of flammable or explosive gases.
- 3. Enclosure "IP65" applies only to the front face of the panel when mounting. Do not use in an environment where oil splashing or spraying is anticipated.

Mounting

1. Mounting with bracket


Mount the bracket on the body with two M3 \times 5L mounting screws.

Tighten the bracket mounting screws at a tightening torque of 0.5 to 0.7 N·m.



2. Mounting with panel mount adapter

Secure the panel mount adapter with two M3 x 8L mounting screws.




Mounting

⚠ Caution

3. Panel mount adapter removal

To remove the controller with panel mount adapter from the equipment, remove the two mounting screws, and pull out the controller while pushing the claws outward.


Failure to follow this procedure can cause damage to the controller and panel mount adapter.




Wiring

1. Connection and removal of sensor connector

- Hold the lever and connector body with two fingers and insert the connector straight into the pin until it is locked with a click sound.
- To remove the connector, pull it out straight while pressing the lever with one finger.



2. Connector pin numbers for power supply/output cable





Specific Product Precautions 3

Be sure to read before handling.

Regulating Pressure Range and Rated Pressure Range


⚠ Caution

Set the pressure within the rated pressure range.

The regulating pressure range is the range of pressure that can be set on the controller.

The rated pressure range is the range of pressure that satisfies the specifications (accuracy, linearity, etc.) of the sensor.

Although it is possible to set a value outside the rated pressure range, the specifications will not be guaranteed even if the value stays within the regulating pressure range.



16-3-31

ZSE□ ISE□

PSE

ZSE3

PS

ZSE;

ZSP

ISA₂

IS□

ZSM

PF2□

 $\mathsf{IF}\Box$

Data

