OMRON Lighted Pushbutton Switch

A3C

А

в

Blue

Black


Cylindrical 12-dia. Series with Superb Operability, High Visibility, and Compact Housing

- Three models of Pushbuttons (round, square, and rectangular), two types of light-emitting elements (LED lamp and incandescent lamp), and two types of Switches (switching standard loads and microloads) available.
- Models that can be used as an indicator also available.
- Requires only 20 mm mounting depth
- Efficiency in wiring improved by terminals arranged on the same surface.
- All LED lamps, incandescent lamps, caps, and legends replaceable without tools.
- UL (E41515) and CSA (LR45258) approved.

Ordering Information -

Model Number Legend

When placing your order, specify the individual component part model numbers of the Pushbutton, Lamp (lighted models only), and Switch, as listed in the ordering tables below.





Ordering as a Set

The model numbers used to order sets of Units are given in the following tables. One set comprises the Pushbutton, Lamp (lighted models only), and Switch.

Rectangular Models









Lighted Pushbutton Switches (SPST-NO+SPST-NC Solder Terminals)

	Contact type		ard load	Microload	Pushbutton color
Shape	Operation Lighting	Momentary operation (Self-resetting)	Alternate operation (Self-holding)	Momentary operation (Self-resetting)	symbol
Rectangular (A3CJ)	LED lamp	A3CJ-90A1-05E	A3CJ-90B1-05E	A3CJ-90E1-05E	R: red
		A3CJ-90A1-12E	A3CJ-90B1-12E	A3CJ-90E1-12E	Y: yellow G: green
		A3CJ-90A1-24E	A3CJ-90B1-24E	A3CJ-90E1-24E	W: white
	Incandescent lamp	A3CJ-90A1-06			R: red
		A3CJ-90A1-14			Y: yellow G: green
		A3CJ-90A1-28	-		W: white A: blue
	Non-lighted	A3CJ-90A0-	A3CJ-90B0-	A3CJ-90E0-	B: black (See note 3.)
Square (A3CA)	LED lamp	A3CA-90A1-05E	A3CA-90B1-05E	A3CA-90E1-05E	R: red Y: yellow G: green W: white
		A3CA-90A1-12E	A3CA-90B1-12E	A3CA-90E1-12E	
		A3CA-90A1-24E	A3CA-90B1-24E	A3CA-90E1-24E	
	Incandescent lamp	A3CA-90A1-06			R: red
		A3CA-90A1-14			Y: yellow G: green
		A3CA-90A1-28	1		W: white A: blue
	Non-lighted	A3CA-90A0-	A3CA-90B0-	A3CA-90E0-	B: black (See note 3.)
Round (A3CT)	LED lamp	A3CT-90A1-05E	A3CT-90B1-05E	A3CT-90E1-05E	R: red
		A3CT-90A1-12E	A3CT-90B1-12E	A3CT-90E1-12E	Y: yellow G: green
		A3CT-90A1-24E	A3CT-90B1-24E	A3CT-90E1-24E	W: white
	Incandescent lamp	A3CT-90A1-06			R: red
		A3CT-90A1-14]		Y: yellow G: green
		A3CT-90A1-28			W: white A: blue
	Non-lighted	A3CT-90A0-	A3CT-90B0-	A3CT-90E0-	B: black (See note 3.)


Note: 1. Enter the desired color symbol for the Pushbutton in the \Box at the end of the model number.

2. There are also alternate-operation models that can be used for microloads. Refer to the Switch table on page 37.


3. Black ("B") Pushbuttons are only available for non-lighted models.

Illumination-only and Colored-illumination LED Models

"Illumination only" describes LED models for which the screen color is the same whether the LED is lit or not. The screen simply becomes brighter when the LED lights.



"Colored illumination" describes LED models for which the screen color is white when the LED is not lit and changes to the color of the LED lamp when the LED is lit.



Ordering: With colored-illumination models, order the Pushbutton, Lamp, and Switch as shown in the following table.

Illuminated color	Pushbutton	Lamp	(LED)	Switch
Red	IP40 A3C□-500W	A16-□DR	Enter one of the following symbols in \Box .	Refer to the following information. Order the
Yellow	Enter one of the following symbols in . J: Rectangular	A16-□DY	5: 5 VDC 12: 12 VDC 24: 24 VDC	Switch that is appropriate for the Pushbutton.
Green	A: Square T: Round	A16-□DG		

Ordering Individually

Pushbuttons, Lamps, and Switches can be ordered separately. Combinations that are not available as sets can be created using individual Units. Also, store the parts as spares for maintenance and repairs.

Pushbuttons

LED Lamp

Button color	Rectangular	Square	Round
			Q
	T	<u>L</u>	F
Red	A3CJ-500R	A3CA-500R	A3CT-500R
Yellow	A3CJ-500Y	A3CA-500Y	A3CT-500Y
Green	A3CJ-500GY	A3CA-500GY	A3CT-500GY
White	A3CJ-500W	A3CA-500W	A3CT-500W

Note: The red, yellow, and white Pushbuttons listed above can be used with either LED lamp-lighted models or incandescent lamp-lighted models.

Incandescent Lamp

Button color	Rectangular	Square	Round
Red	A3CJ-500R	A3CA-500R	A3CT-500R
Yellow	A3CJ-500Y	A3CA-500Y	A3CT-500Y
Green	A3CJ-500G	A3CA-500G	A3CT-500G
White	A3CJ-500W	A3CA-500W	A3CT-500W
Blue	A3CJ-500A	A3CA-500A	A3CT-500A

Lamps

LED Lamp

Color		Rated voltage				
	5 VDC	12 VDC	24 VDC			
Red	A16-5DR	A16-12DR	A16-24DR			
Yellow	A16-5DY	A16-12DY	A16-24DY			
Green	A16-5DG	A16-12DG	A16-24DG			
White	A16-5DW	A16-12DW	A16-24DW			

Incandescent Lamp

Rated voltage	6 VAC/VDC	14 VAC/VDC	28 VAC/VDC
Model	A16-5	A16-12	A16-24

Switches

Configuration	Contact	Switch action Terminal		De	gree of protection	: IP40
				Rectangular	Square	Round
Standard	SPST-NO+	Momentary	Solder	A3CJ-7011	A3CA-7011	A3CT-7011
	SPST-NC	Alternate		A3CJ-7021	A3CA-7021	A3CT-7021
Microload		Momentary		A3CJ-7111	A3CA-7111	A3CT-7111
		Alternate		A3CJ-7121	A3CA-7121	A3CT-7121

Non-lighted Models

Button color	Rectangular	Square	Round
Red	A3CJ-500R	A3CA-500R	A3CT-500R
Yellow	A3CJ-500Y	A3CA-500Y	A3CT-500Y
Green	A3CJ-500G	A3CA-500G	A3CT-500G
White	A3CJ-500W	A3CA-500W	A3CT-500W
Blue	A3CJ-500A	A3CA-500A	A3CT-500A
Black	A3CJ-501B	A3CA-501B	A3CT-501B

Name Appearance Classification Model Remarks Socket Cannot be used with Insulation Cover. Wire-wrap terminal A3C-4101 PCB terminal A3C-4102 Solder terminal A3C-4103 Insulation A3C-3002 ---Cannot be used with Socket. Cover Switch Cannot be used with Dust Cover. For rectangular models A3CJ-5050 Guard For square, round models A3CA-5050 **Dust Cover** A3CJ-5060 Cannot be used with Switch Guard. For rectangular models Tightening ---A3C-3004 The tightening torque is 0.20 to Tool 0.39 N·m. A3PJ-5080 Extractor ---Legend For rectangular models A3CJ-5201 One Legend Plate is supplied per Plate standard Switch. For square models A3CA-5201 For round models A3CT-5201

Accessories (Order Separately)

Specifications Contact Ratings

Model	ltem		
	AC resistive load	DC resistive load	
Standard load	0.5 A at 250 VAC 1 A at 125 VAC	1 A at 30 VDC	
Microload (See note 1.)	0.1 A at 125 VAC	0.1 A at 30 VDC	

Note: 1. The minimum permissible load is 1 mA, 5 VDC.

2. The above ratings are for testing under the following conditions:

1) Load: Resistive load

2) Mounting conditions: No vibrations or shock

3) Temperature: $20^{\circ}C \pm 2^{\circ}C$

4) Operation frequency: 20 operations/minute

LED Lamp Ratings

Rated voltage	Rated current	Operating voltage	Internal limiting resistance
5 VDC	30 mA	5 VDC±5%	33 Ω
12 VDC	15 mA	12 VDC±5%	270 Ω
24 VDC	10 mA	24 VDC±5%	1,600 Ω

Incandescent Lamp Ratings

Rated voltage	Rated current	Operating voltage
6 VAC/VDC	60 mA	5 VAC/VDC
14 VAC/VDC	40 mA	12 VAC/VDC
28 VAC/VDC	24 mA	24 VAC/VDC

Characteristics

Operating frequency	Mechanical: Momentary-action models: 120 operations/minute max. Alternate-action models: 60 operations/minute max. (See note 1.) Electrical: 20 operations/minute max.
Insulation resistance	100 MΩ min. (at 500 VDC)
Dielectric strength	1,000 VAC, 50/60 Hz for 1 minute between terminals of same polarity and between lamp terminals (See note 2.) 2,000 VAC, 50/60 Hz for 1 minute between terminals of different polarity and also between each terminal and ground
Vibration	Malfunction: 10 to 55 Hz, 1.5-mm double amplitude (No malfunctions for more than 1 s.)
Shock	Destruction: 500 m/s ² Malfunction: 150 m/s ² (No malfunctions for more than 1 s.)
Life expectancy	Mechanical: Momentary-action models: 1,000,000 operations min. Alternate-action models: 100,000 operations min. (See note 1.) Electrical: 100,000 operations min.
Weight	Approx. 5 g (See note 3.)
Ambient operating temperature	-10°C to 55°C (with no icing or condensation)
Ambient operating humidity	35% to 85%
Ambient storage temperature	–25°C to 65°C
Degree of protection	IP40
Electric shock protection class	Class II
PTI (proof tracking index) 175	
Pollution degree	3 (IEC947-5-1)

Note: 1. With alternate-operation models, one operation cycle consists of set and reset operations.

- 2. The figure given above for the dielectric strength between lamp terminals is for when there is no LED lamp or incandescent lamp mounted.
- 3. The weight indicated here applies to the lighted models (SPST-NO+SPST-NC).

Operating Characteristics

OF max.	2.45 N
RF min.	0.29 N
тт	Approx. 3.5 mm
LTA min. (See note.)	0.5 mm
PT max.	2.5 mm

Note: The value for LTA min. applies to alternate-operation models only.

Contact Form

Contact name	Contact form		
SPDT	NO NO		

Approved by Standards

UL (File No. E41515) CSA (File No. LR45258-31)


Rating Standard

1 A at 125 VAC 0.5 A at 250 VAC 1 A at 30 VDC

Microload

0.1 A at 125 VAC 0.1 A at 30 VDC


Nomenclature Color cap Legend Plate (milky white) Reflective plunger **Pushbutton Color of Pushbutton** Shape of Pushbutton LED lamp-lighted Models: • Rectangular Square (A3CA) Round (A3CT) Red, yellow, green, white (A3CJ) Incandescent lamp-lighted Models: ٠ Red, yellow, green, white, blue Non-lighted Models: ٠ Red, yellow, green, white, blue, black Lamp LED Lamp Incandescent Lamp Switch Standard load: 0.5 A at 250 VAC 1 A at 125 VAC 1 A at 30 VDC • Microload: 0.1 A at 125 VAC, 0.1 A at 30 VDC Minimum applicable load: 1 mA at 5 VDC





Dimensions -

The following dimensions apply to the Switch with SPST-NO+SPST-NC contact configuration, with solder terminals.

14 11.8







9.5 - - 2 - - - - - - - - - 2

20

-0.6


-0.6

Ð

M12×1


-9.5-


-1



+11.8-


-14





Round Models A3CT






2	6.5

A3C

Accessory Mounting Dimensions

Dimensions with Socket Mounted

The diagrams below show the external dimensions for rectangular models as representative models.



legend.

22.5

Panel Cutout (Top View)

Accessories used	Rectangular/A3CJ	Square/A3CA, Round/A3CT		
Switch only	Note: Recommended panel thickness: 1.0 to 3.2 mm.	Note: Recommended panel thickness: 1.0 to 3.2 mm.		
With Switch Guard	12 dia: 22.5 min. 7.5±0.1 2 dia. 5.5±0.1 19 min.	12 dia:+02 		
With Dust Cover	12 dia: ^{40,2} 23.5 min 2 dia. 5.5±0.1 19.5 min. 19.5 min.			

Note: If the panel is to be finished (e.g., coated), make sure that the panel meets the specified dimensions after the coating.

Operation ——

Terminal Connections

Terminal	Туре				
	SPST-NO+SPST-NC				
Solder terminal	Lighted and non-lighted models				

Installation


A3C

Mounting and Replacing the Pushbutton

Mounting Direction for the Pushbutton/Display and Lamp


Lighted Pushbutton Switch

• Insert the Lamp (incandescent lamp or LED lamp) into the Pushbutton so that the lamp guide fits into the wider gap between the projections on the Pushbutton.



Indicator


• With Indicators, the Lamp is inserted facing the opposite direction (i.e., at 180°) to that for Lighted Pushbutton Switches.



Projection of the LED/lamp

- **Note:** 1. Push the projections on the Lamp into the grooves on the Pushbutton/Display.
 - 2. The Lamp for Lighted Pushbutton Switches moves, but the Lamp for Indicators is fixed.

Mounting Direction for the Pushbutton/Display and Switch Insert the Pushbutton/Display into the Switch so that the lamp guide is aligned with the non-projecting part of the Switch. Apply a pressure between 9.8 and 24.5 N.




Note: 1. The mounting direction for Indicators is 180° to that for Lighted Pushbutton Switches. Be sure to insert the Legend Plate and other parts with the correct orientation.

- 2. If the terminals of the Lamp become bent, it may be impossible to fit them into the lamp terminal holes. Ensure that the terminals are straight when they are inserted.
- 3. Take particular care about the mounting direction with the round models (A3CT).

Removing the Pushbutton/Display

Hold the recessed portions on the cap of the Pushbutton and pull.




Note: Do not use tools such as pliers to remove the Pushbutton as this may damage the cap.

Panel Mounting

Insert the Switch from the front of the panel. Mount the mounting nut from the terminal end of the Switch and tighten it.

There are projections on the terminal end of the Switch which may, depending on the orientation, block the nut. In this case, turn the nut until it is possible to mount it. Tighten the nut to a torque between 0.20 and 0.39 N·m.


If soldering is used, mount the mounting nut first. Lead wires and mounds of solder may make it impossible to mount the nut after soldering.




Socket Mounting

After securing the Switch to the panel using the mounting nut, insert the Socket into the Switch.

Align the positioning holes of the Socket with the projections of the Switch before inserting the Socket.






Mounting the Insulation Cover


After securing the Switch to the panel using the mounting nut, pass the lead wires through the holes in the Insulation Cover and then perform wiring. Hold the Insulation Cover so that the cylindrical hole is facing the Switch, and insert the lead wires from the end with the barriers.

After wiring is completed, mount the Insulation Cover by pushing it into the Switch.




Mounting the Dust Cover

- 1. The Dust Cover separates into 2 parts: the cap and the mounting frame.
- 2. Insert the Switch into the mounting frame. (Align the lock projection with the recess on the mounting frame.)
- 3. Insert the Switch in the state described in step 2 into the panel. (Align the lock protrusion on the mounting frame with the hole in the panel.)
- 4. Mount the mounting nut from the back of the panel and tighten it.
- Insert the cap into the mounting frame. Ensure that the entire perimeter of the cap is properly inserted into the mounting frame by pressing down on the cap from different directions.



Mounting the Switch Guard

- 1. Insert the Switch into the Switch Guard.
- 2. Insert the Switch into the panel in the state described in step 1.
- 3. Mount the mounting nut from the back of the panel and tighten it.



Precautions

Do not apply a voltage higher than the maximum rated operating voltage between the lamp terminals, as there is a risk that the incandescent lamp or LED lamp will be damaged, and the Pushbutton will be ejected.

When replacing the incandescent lamp, first turn OFF the power supply, and then wait 10 minutes before performing replacement, as the lamp is still hot immediately after the power is turned OFF, so there is a risk of burns.

Refer to the *Common Precautions* for Pushbutton Switches on page 14.

Correct Use

Mounting

To prevent electric shock or a fire, always make sure that the power is turned OFF before mounting, removing, or wiring the Switch, or performing maintenance.

Do not tighten the mounting ring excessively using pliers or a similar tool. Excessive tightening may damage the mounting ring. (Tightening torque: 0.20 to 0.39 $N{\cdot}m)$

Wiring

When wiring, use wires of a size appropriate for the applied voltage and carry current. Perform soldering correctly under the conditions given below. Using the Switch with the wires soldered incorrectly may cause the terminals to become abnormally hot and cause a fire.

- 1. Hand soldering: At 30 W within 5 seconds.
- 2. Dip soldering: At 240°C within 3 seconds.

Wait for one minute after soldering before exerting any external force on the solder.

Use a non-corrosive rosin liquid for the flux.

Perform wiring so that the wire sheaths do not come into contact with the Switch. If this is unavoidable, use wires that can withstand temperatures of 100° C min.


After wiring to the Switch has been completed, ensure an appropriate insulation distance.

Operating Environment

Do not use in locations that are subject to dust, oil, or metal filings as these may penetrate the interior of the Switch and cause malfunction.

Using Microloads

Using a standard load switch for opening and closing a microload circuit may cause wear on the contacts. Use the switch within the operating range. (Refer to the diagram below.) Even when using microload models within the operating range shown below, if inrush current occurs when the contact is opened or closed, it may cause the contact surface to become rough, and so decrease life expectancy. Therefore, insert a contact protection circuit where necessary. The minimum applicable load is the N-level reference value. This value indicates the malfunction reference level for the reliability level of 60% (λ 60) (conforming to JIS C5003). The equation, λ 60 = 0.5 x 10⁻⁴/times indicates that the estimated malfunction rate is less than 1/2,000,000 with a reliability level of 60%.



LED

Resistance to limit the LED current is provided internally and so an external resistance is not required.

Rated voltage	Internal limiting resistance
5 VDC	33 Ω
12 VDC	270 Ω
24 VDC	1600 Ω

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

Cat. No. A030-E1-05

Common Precautions

For the individual precautions for a Switch, refer to the precautions in the section for that Switch.

Cautions


Do not perform wiring or touch the charged parts of terminals while power is being supplied to the Switch. Doing so may result in electric shock.

Electrical Characteristics

Electrical Conditions


- The switching load capacity of the Switch greatly varies between AC and DC. Always be sure to apply the rated load. The control capacity will drastically drop if it is a DC load. This is because a DC load has no current zero-cross point, unlike an AC load. Therefore, if an arc is generated, it may continue for a comparatively long time. Furthermore, the current direction is always the same, which results in a contact relocation phenomena whereby the contacts easily stick to each other and do not separate when the surfaces of the contacts are uneven.
- Some types of load have a great difference between normal current and inrush current. Make sure that the inrush current is within the permissible value. The greater the inrush current in the closed circuit is, the greater the contact abrasion or shift will be. Consequently, contact weld, contact separation failures, or insulation failures may result. Furthermore, the Switch may be broken or damaged.
- If the load is inductive, counter-electromotive voltage will be generated. The higher the voltage is, the higher the generated energy will be, which will increase the abrasion of the contacts and contact relocation phenomena. Be sure to use the Switch within the rated conditions.

Inrush Current



- Approximate control capacities are given in ratings tables, but these alone are insufficient to guarantee correct operation. For special types of load, with unusual switching voltage or current waveforms, test whether correct operation is possible with the actual load before application.
- When switching for microloads (voltage or current), use a Switch with microload specifications. The reliability of silver-plated contacts, which are used in Switches for standard loads, will be insufficient for microloads.
- When switching microloads or very high loads that are beyond the switching capacity of the Switch, connect a relay suitable for the load.

Type of Load vs. Inrush Current



- All the performance ratings given are for operation under the following conditions unless otherwise specified.
 - Inductive load: A minimum power factor of 0.4 (AC) and a maximum time constant of 7 ms (DC)

Lamp load:	An inrush current	10 times	higher	than	the
	steady-state currer	nt			


- Motor load: An inrush current 6 times higher than the steady-state current
- **Note:** Inductive loads can cause problems especially in DC circuitry. Therefore, it is essential to know the time constants (L/R) of the load.

Load Connections

Do not contact a single Switch to two power supplies that are different in polarity or type.

Connection of Different Polarities

The power supply may short-circuit if the loads are connected in the way shown in the "incorrect" example below.




Even in the "correct" example, note that the insulation performance of the switch may deteriorate and the switch life may be shortened because loads are connected to both contacts.

Connection of Different Power Supplies


The DC and AC power may be mixed for the circuit shown below.

Incorrect



Do not design a circuit where voltage is imposed between contacts, otherwise contact weld may result.

Incorrect



Contact Protective Circuit

Apply a contact protective circuit to extend the contact life, prevent noise, and suppress the generation of carbide or nitric acid. Be sure to apply the contact protective circuit correctly, otherwise an adverse effect may occur.

The following provides typical examples of contact protective circuits. If the Limit Switch is used in an excessively humid location for switching a load that easily generates arcs, such as an inductive load, the arcs may generate NOx, which will change into HNO_3 if it reacts with moisture. Consequently, the internal metal parts may corrode and the Limit Switch may fail. Be sure to select the ideal contact preventive circuit from the following.

Typical Examples	s of	Contact	Protective	Circuits
-------------------------	------	---------	------------	----------

Circuit example		uit example Applicab current		Feature	Element selection	
		AC	DC			
CR circuit	C R Inductive Supply	*	Yes	*When AC is switched, the load impedance must be lower than the CR impedance.	C: 1 to 0.5 μ F x switching current (A) R: 0.5 to 1 Ω x switching voltage (V) The values may change according to the characteristics of the load. The capacitor suppresses the spark discharge of current when the contacts are open. The resistor limits	
	C Power supply R	Yes	Yes	The operating time will be greater if the load is a relay or solenoid. Connecting the CR circuit in parallel to the load is effective when the power supply voltage is 24 or 48 V and in parallel to the contacts when the power supply voltage is 100 to 200 V.	the inrush current when the contacts are closed again. Consider the roles of the capacitor and resistor and determine ideal capacitance and resistance values through testing. Basically, use a capacitor with a dielectric strength between 200 and 300 V. When AC is switched, make sure that the capacitor has no polarity.	
Diode method	Power supply	No	Yes	Energy stored in the coil is changed into current by the diode connected in parallel to the load. Then the current flowing to the coil is consumed and Joule heat is generated by the resistance of the inductive load. The reset time delay with this method is longer than that in the CR method.	The diode must withstand a peak inverse voltage 10 times higher than the circuit voltage and a forward current as high or higher than the load current.	
Diode and Zener diode method	Power supply	No	Yes	This method will be effective if the reset time delay caused by the diode method is too long.	Use a Zener diode with a Zener voltage that is approximately $1.2 \times$ power supply voltage as, depending on the environment, the load may not operate.	
Varistor method	Power supply	Yes	Yes	This method makes use of constant-voltage characteristic of the varistor so that no high-voltage is imposed on the contacts. This method causes a reset time delay. Connecting a varistor in parallel to the load is effective when the supply voltage is 24 to 48 V and in parallel to the contacts when the supply voltage is 100 to 200 V.		

Do not apply contact protective circuits as shown below. Incorrect



This circuit effectively suppresses arcs when the contacts are OFF. The capacitor will be charged, however, when the contacts are OFF. Consequently, when the contacts are ON again, short-circuited current from the capacitance may cause contact weld.

Incorrect



This circuit effectively suppresses arcs when the contacts are OFF. When the contacts are ON again, however, charge current will flow to the capacitor, which may result in contact weld.

Switching a DC inductive load is usually more difficult than switching a resistive load. By using an appropriate contact protective circuit, however, switching a DC inductive load will be as easy as switching a resistive load.

Switching


- Do not use the Switch for loads that exceed the rated switching capacity or other contact ratings. Doing so may result in contact weld, contact separation failures, or insulation failures. Furthermore, the Switch may be broken or damaged.
- Do not touch the charged switch terminals while power is supplied, otherwise an electric shock may be received.
- The life of the Switch varies greatly with switching conditions. Before using the Switch, be sure to test the Switch under actual conditions. Make sure that the number of switching operations is within the permissible range. If a deteriorated Switch is used continuously, insulation failures, contact weld, contact failures, switch damage, or switch burnout may result.
- Do not apply excessive or incorrect voltages to the Switch or incorrectly wire the terminals. Otherwise, the Switch may not function properly and have an adverse effect on external circuitry. Furthermore, the Switch itself may become damaged or burnt.
- Do not use the Switch in locations where flammable or explosive gases are present. Otherwise switching arcs or heat radiation may cause a fire or explosion.
- Do not drop or disassemble the Switch, otherwise it may not be capable of full performance. Furthermore, it may be broken or burnt.

Mechanical Conditions


Operating Force and Operating Method

Fingertip operation is an important feature of Pushbutton Switches. In terms of Switch operation, Pushbutton Switches differ greatly from detection switches such as Microswitches. Operating the Switch using a hard object (e.g., metal), or with a large or sudden force, may deform or damage the Switch, resulting in faulty or rough operation, or shortening of the Switch life. The strength varies with the size and construction of the Switch. Use the appropriate Switch for the application after confirming the operating method and operating force with this catalog.






 The pushbutton surface is composed of resin. Therefore, do not attempt to operate the pushbutton using a sharp object, such as a screwdriver or a pair of tweezers. Doing so may damage or deform the pushbutton surface and result in faulty operation.




Mounting

- Switches can be broadly divided into two categories according to mounting method: panel-mounting models and PCB-mounting models. Use the appropriate model for the mounting method required. Basically, panel-mounting Switches can withstand a greater operating force than PCB-mounting Switches. If, however, the panel thickness or the panel-cutout dimensions are not suitable for the Switch, it may not be able to withstand the normal operating force. With continuous mounting in particular, select a panel of a thickness that is easily sufficient to withstand the total operating force.
- Panel-mounting Switches can be divided into two categories according to the mounting method: snap-in mounting models and screw-mounting models. Snap-in mounting Switches are held in place with the elasticity of resin or a metal leaf spring. Do not attempt to modify the spring after mounting. Doing so may result in faulty operation or damage the mounting structure. Mount screw-mounting models using the screws and nuts provided (or individually specified). Tighten the screws to the specified torque. Mounting with different screws or nuts, or tightening beyond the specified torque may result in distortion of the inside of the case or damage to the screw section.



 Subjecting the Switch to severe vibrations or shock may result in faulty operation or damage. Also, many of the Switches are composed of resin so contact with sharp objects may result in damage to the surface. This kind of damage may spoil the appearance of the Switch or result in faulty operation. Do not throw or drop the Switch.



Incorrect

Hammer


Do not operate the Switch with heavy or sharp objects.

Mounting Precautions


Screwdriver

Wiring

Perform wiring so that the lead wires will not be caught on other objects as this will cause stress on the Switch terminals. Wire the Switch so that there is slack in the lead wires and fix lead wires at intermediate points. If the panel to which the Switch is mounted needs to be opened and closed for maintenance purposes, perform wiring so that the opening and closing of the panel will not interfere with the wiring.



 With miniature Switches, the gap between the terminals is very narrow. Use protective or heat-absorbing tubes to prevent burning of the wire sheath or shorting.




Soldering

• There are two methods for soldering the Switch: hand soldering and automatic soldering. In addition, automatic soldering itself can be divided into two types : dip soldering and reflow soldering. Use the soldering method appropriate for the mounting method.


The following table gives some examples of applications using the types of soldering given above.

Method		Soldering device	Application	
Hand solde	ring	Soldering iron	Small quantities	
			Different materials	
			Lead wire terminals	
Automatic soldering	Dip soldering	Jet soldering bath	Large quantities of discrete	
		Dip soldering bath	terminals	
	Reflow soldering	Infrared reflow (IR) soldering bath	Large quantities of miniature SMD terminals	
		Vapor-phase (VPS) reflow soldering bath		


- Do not use soldering flux that contains chlorine. Doing so may result in metal corrosion.
- Perform hand soldering using the appropriate soldering iron.




 With the exception of PCB-mounting Switches, when performing hand soldering, hold the Switch so that the terminals point downwards so that flux does not get inside the Switch.



• Leave a gap of at least 1 mm between the soldered parts and the surface of the case so that flux does not get inside the Switch.




 When applying flux using a brush, use a sponge soaked in flux as shown below. Do not apply more than is necessary. Also, apply the flux with the PCB inclined at an angle of less than 80° so that flux does not flow onto the mounting surface of the Switch.




 Do not place PCBs that have had flux applied or have been soldered on top of each other. Otherwise, the flux on the PCB's solder surface may stain the upper part of the Switch or even permeate the inside of the Switch and cause contact failure.






Do not place PCBs with solder or flux on top of each other. • When performing soldering with a dip soldering bath, ensure that the flux does not reach a higher level than the PCB.




• Flux is especially likely to rise up at the edges of the PCB. If the Switch is mounted near the edge of the PCB, create a gap between the edge by using a split PCB, and insert the PCB in the soldering bath so that the edge that is farthest from the Switch enters the bath first.



Storage

• When the Switch is left unused or stored for long periods, the ambient conditions can have a great effect on the condition of the Switch. In certain environments, leaving the Switch exposed may result in deterioration (i.e., oxidation, or the creation of an oxide film) of the contacts and terminals, causing the contact resistance to increase, and making it difficult to solder the lead wires. Therefore, store in a well-ventilated room, inside, for example, a non-hygroscopic case, in a location where no corrosive gases are present.



• If the Switch is stored in a location where it will be exposed to direct light, colored resin in the colored plate may fade. Therefore, do not store the Switch in locations where it will be exposed to direct light.